



NOTES

- UTILITY CORRIDOR (HYDRO & TELECOMMUNICATIONS) SHALL BE 0.6m WIDE.
- UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
- WATERMAIN TO HAVE MINIMUM COVER OF 2.0m FOR 300mm AND SMALLER DIAMETER AND 1.8m FOR 450mm DIAMETER AND LARGER.
- CLEAR SEPARATION BETWEEN WATERMAIN AND SEWERS SHALL BE AS PER MOE REQUIREMENTS.
- JOINT USE TRENCHES SHALL BE USED BY HYDRO AND TELECOMMUNICATION.
- THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION TO DETERMINE IF ADDITIONAL THICKNESS IS REQUIRED.
 40mm HL3
 100mm HL4
 150mm GRANULAR "A"
 450mm GRANULAR "B"
- SUB-GRADE SHALL BE COMPACTED TO 100% OF STANDARD PROCTOR DENSITY AT MAX. DRY DENSITY.

26.0m MAJOR COLLECTOR R.O.W.

The Corporation Of The
**CITY OF
KITCHENER**



			SCALE:	N.T.S.
			DATE:	JUNE 2010
1	MANUAL UPDATE	JULY 2012		
NO.	REVISION	DATE	STANDARD No.:	102