



NOTES

1. UTILITY CORRIDOR (HYDRO & TELECOMMUNICATIONS) SHALL BE 0.6m WIDE.
2. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
3. WATERMAIN TO HAVE MINIMUM COVER OF 2.0m FOR 300mm AND SMALLER DIAMETER AND 1.8m FOR 450mm DIAMETER AND LARGER.
4. CLEAR SEPARATION BETWEEN WATERMAIN AND SEWERS SHALL BE AS PER MOE REQUIREMENTS.
5. JOINT USE TRENCHES SHALL BE USED BY HYDRO AND TELECOMMUNICATION.

6. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION TO DETERMINE IF ADDITIONAL THICKNESS IS REQUIRED.  
40mm HL3  
100mm HL4  
150mm GRANULAR "A"  
450mm GRANULAR "B"
7. SUB-GRADE SHALL BE COMPACTED TO 100% OF STANDARD PROCTOR DENSITY AT MAX. DRY DENSITY.
8. REFER TO REGION OF WATERLOO STANDARD DRAWING 211 FOR BOULEVARD CONCRETE EDGE STRIP DETAILS.

30.0m SECONDARY ARTERIAL R.O.W.

The Corporation Of The  
**CITY OF  
KITCHENER**



			SCALE:	N.T.S.
			DATE:	JUNE 2010
1	MANUAL UPDATE	JULY 2012		
NO.	REVISION	DATE	STANDARD No.:	103