


NOTE TO BUILDER AND PLUMBER

- (1) BRING 1" SERVICE INTO ALL RESIDENTIAL DWELLINGS AND REDUCE TO 3/4" AT FIRST STOP.
- (2) ALL METERS MUST BE ACCESSIBLE FOR READING AND REPLACEMENT. ANY OBSTRUCTIONS WILL BE BASIS FOR TERMINATION OF THE WATER SUPPLY.
- (3) ALL WATER METERS ARE MARKED WITH A FLOW DIRECTIONAL ARROW. PLEASE ENSURE ARROW CORRESPONDS WITH WATER FLOW.
- (4) REMOVE METER COUPLINGS & GASKETS FROM THE METER BEFORE SOLDERING. HEAT AND SOLDER WILL DAMAGE THE INNER COMPONENTS OF THE WATER METER.
- (5) ALL METER SETS MUST HAVE A SHUT OFF VALVE BEFORE AND AFTER THE METER AND DRAIN VALVE, AS DRAWING INDICATES.
- (6) ALL WATER METERS MUST BE INSTALLED ON HORIZONTAL PLANE USING THE SUPPLIED METER COUPLINGS AND GASKETS.
- (7) A BY-PASS MUST BE ADDED IF THE WATER METER IS A COMMERCIAL, INSTITUTIONAL, INDUSTRIAL OR MULTI-RESIDENTIAL SET.
- (8) METER SET AND BY-PASS TO BE RIGID PIPING AND SUPPORTED.
- (9) BACKFLOW PREVENTORS AND PRESSURE REDUCING VALVES MUST BE INSTALLED AFTER METER SET.
- (10) CALL 519-741-2600X 4537 FOR FURTHER ASSISTANCE.

TABLE

SIZE OF METER	A	B
5/8"	12"-18"	6"

RESIDENTIAL 5/8" METER SET		 Kitchener Utilities	
DRAWN: JTP	SCALE: NTS		
CHECKED:	DATE: JUNE 14 2019		