



DELETED

- NOTES -
1. ALL CONCRETE TO BE 20 MP<sub>a</sub>.
  2. MIN. 25mm THICK CASTING PLATE ON CHAMBERS LOCATED IN TRAVELLED PORTION OF ROAD.
  3. ALL MATERIAL PLACED AROUND CHAMBER TO BE PROPERLY COMPACTED.
  4. A/R-AS REQUIRED BY LOAD AND SITE CONDITIONS.

DIMENSIONAL STANDARDS  
FOR POURED VALVE CHAMBER  
(FOR 600mm GATE VALVE)

The Corporation Of The  
**CITY OF  
KITCHENER**



			Scale:	N.T.S.
			Rev. Date:	JUNE 2010
No.	REVISION	DATE	Std. No.:	202