



- NOTES—1. CHAINAGE TO BE WATERMAIN CHAINAGE
NOT ϕ OF THE ROAD.
2. A MIN. OF 2 TIES AT RIGHT ANGLES OR LESS
ARE REQUIRED FOR VALVES AND FITTINGS OTHER
THAN CURB STOPS.
3. MEASUREMENTS BETWEEN CURB STOPS ON
CURVES ARE TO BE CHORD MEASUREMENTS.

| | | | | |
|--|--|---|------------|-----------|
| STANDARD AS BUILT MEASUREMENT FOR WATERMAIN CONSTRUCTION | The Corporation Of The CITY OF KITCHENER |  | Scale: | N.T.S. |
| | | | Rev. Date: | JUNE 2010 |
| | | | Std. No.: | 205 |
| No. | REVISION | DATE | | |