



NOTES

1. UTILITY CORRIDOR (HYDRO & TELECOMMUNICATIONS) SHALL BE 0.6m WIDE.
2. UTILITY CORRIDOR TO HAVE A MINIMUM COVER OF 0.9m.
3. WATERMAIN TO HAVE MINIMUM COVER OF 2.0m FOR 300mm AND SMALLER DIAMETER AND 1.8m FOR 450mm DIAMETER AND LARGER.
4. CLEAR SEPARATION BETWEEN WATERMAIN AND SEWERS SHALL BE AS PER MOE REQUIREMENTS.
5. MINIMUM SEPARATION BETWEEN THE SANITARY AND STORM SEWERS SHALL NOT BE LESS THAN 1.5m.
6. JOINT USE TRENCHES SHALL BE USED BY HYDRO AND TELECOMMUNICATION.
7. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATION TO DETERMINE IF ADDITIONAL THICKNESS IS REQUIRED.
 - 40mm HL3
 - 60mm HL4 (100mm FOR BUS ROUTES)
 - 150mm GRANULAR "A"
 - 400mm GRANULAR "B"
8. SUB-GRADE SHALL BE COMPACTED TO 100% OF STANDARD PROCTOR DENSITY AT MAX. DRY DENSITY.

18.0m LOCAL R.O.W.

The Corporation Of The
**CITY OF
KITCHENER**



			SCALE:	N.T.S.
2	MANUAL UPDATE	APRIL 2015	DATE:	JUNE 2010
1	MANUAL UPDATE	JULY 2012		
NO.	REVISION	DATE	STANDARD No.:	100