



INSULATION OF SEWERS

NOTES:

1. Extruded Polystyrene Insulation to be 50mm thick Multi-purpose STYROFOAM Brand SM Insulation with shiplap edge treatment or approved equivalent.
  2. Trench width dimensions to conform to Region of Waterloo Standard Drawing SSMS E1-01.
  3. Granular 'A' bedding to extend to a minimum of 1500mm below finished grade.
  4. Insulation along trench side slope to extend all the way to the bottom of the bedding.
  5. Minimum bedding depth to conform to Region of Waterloo Standard Drawing SSMS E1-01.
  6. When the spring line of the pipe is below 1.5m insulation is not required.
- A. All dimensions are in millimetres unless otherwise shown.