



DELETED

- NOTES -
1. ALL CONCRETE TO BE 20 MPa.
 2. MIN. 25mm THICK CASTING PLATE ON CHAMBERS LOCATED IN TRAVELLED PORTION OF ROAD.
 3. ALL MATERIAL PLACED AROUND CHAMBER TO BE PROPERLY COMPACTED.
 4. A/R-AS REQUIRED BY LOAD AND SITE CONDITIONS.

DIMENSIONAL STANDARDS FOR POURED VALVE CHAMBER (FOR 450mm GATE VALVE)	The Corporation Of The CITY OF KITCHENER			Scale:	N.T.S.
				Rev. Date:	JUNE 2010
			No.	REVISION	DATE
			Std. No.:	201	